



1. FULL SUPPORT FOUNDATION WALL PER ARCHITECTURAL PLANS AND SPECIFICATIONS.
2. **ANCHORAGE:**
 ANCHORS ARE DESIGNED TO HOLD STONE IN PLACE. BUT WILL NOT SUPPORT THE WEIGHT.
 - A. STAINLESS STEEL CRAMP ANCHOR
 - B. STAINLESS STEEL SPLIT TAB ANCHOR WITH 90° BEND AT OPPOSITE END FROM TABS TO SECURE TO BACK-UP.
 (REFER TO ANCHORAGE SECTION FOR ADDITIONAL INFORMATION)
3. INSULATION BY OTHERS AND PER ARCHITECTURAL DRAWINGS.
4. **CONTINUOUS RELIEF ANGLE:**
 DESIGNED TO SUPPORT THE WEIGHT OF THE STONE. MUST BE VERTICALLY SPACED NO MORE THAN 25'-0" O.C. AND RUN CONTINUOUS ON A HORIZONTAL JOINT. THE VERTICAL LEG TO BE SECURELY FASTENED TO THE BUILDING STRUCTURE, PER THE ENGINEER OF RECORD'S (EOR) RECOMMENDATIONS.
5. STEEL STUD BACK-UP WALL SYSTEM PER ARCHITECTURAL AND STRUCTURAL DRAWINGS AND SPECIFICATIONS AND STUD MANUFACTURER'S REQUIREMENTS.
6. **1" MINIMUM AIRSPACE** BETWEEN THE BACK OF STONE AND BUILDING COMPONENTS. THIS SPACE MUST BE KEPT FREE OF ANY MATERIALS OR DEBRIS (EXCEPT FOR STONE ANCHORING AND SUPPORT) TO ALLOW FOR THE FACE OF STONE TO BE SET PLUMB.
7. STONE VENEER: COLOR AND FINISH PER ARCHITECTURAL DRAWINGS AND SPECIFICATIONS.

